

Questions & Answers

Event Information

Number: 2020-018 Addendum 1

Title: TRP Roof Replacement

Type: Invitation for Bid

Issue Date: 2/29/2020

Question Deadline: 3/19/2020 05:00 PM (CT)

Response Deadline: 3/24/2020 02:00 PM (CT)

Notes: Please submit your bid through lonwave under the Line Items tab and upload the appropriate documents under the Response Attachments tab.

A mandatory pre-bid and walkthrough will be held on Friday, March 13, 2020 at 10:00 AM at 11120 W. 65th Street, Shawnee Kansas 66203. Gather in the front of the building.

Copies of the contract documents and specifications may be obtained from: Drexel Technologies; 10840 W. 86th Street; Lenexa, KS 66214-1632 (<http://www.drexeltech.com/>).

Addendum No. 1 consists of the pre-bid agenda and sign-in sheet.

Published Questions

Question	Could you specify type of underlayment that is acceptable. Organic (15lb or 30lb) or synthetic?
Answer	The underlayment is specified in Section 0073100, 2.02.A. Any product that a contractor wants to submit as an approved equal will need to be equivalent or great than the product specified. Alternative "equal" products should be submitted before the cut-off time for questions.
Asked	3/18/2020 02:55 PM (CT)