

**AMENDMENT NUMBER   2   TO THE BID DOCUMENTS**

Amendment Date:   5-21-2020  

**BID DOCUMENT : Waste Water Treatment Plant Dredging and Disposal**

**A. This Amendment shall be considered part of the bid documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original bid documents, this Amendment shall govern and take precedence. BIDDERS MUST SIGN THE AMENDMENT AND SUBMIT IT WITH THEIR BIDS.**

**B. Bidders are hereby notified that they shall make any necessary adjustments in their estimates as a result of this Amendment. It will be construed that each bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.**

Except as described below, the original bid document remains unchanged. The bid documents are modified and/or clarified, as follows:

**Questions/Clarifications**

**Question:** The pond edges are not currently at 3:1 slope. Is it intended that we remove rock, regrade all the pond edges to 3:1 and replace the rock.?

**Answer:** No. The District expect all the vegetation and sludge removed from pond edges and returned to existing slope. The District expects the contractor to document existing slope and submit this information to the District prior to performing work. The District expects the slope to be returned to that mutually agreement upon slope that was submitted prior to work beginning. The District will not dictate means and methods to accomplish this.

**BIDDER MUST ACKNOWLEDGE THIS AMENDMENT BY SIGNING BELOW AND ATTACHING THE SIGNED AMENDMENT TO THE BID FORM:**

Company Name \_\_\_\_\_

Contact Person \_\_\_\_\_

Signature \_\_\_\_\_

Date \_\_\_\_\_

**Kimberly A. Jones**

Director  
Facilities Planning and Management  
Butte Community College District