

MADISON COUNTY, ALABAMA

Christina Watson, Procurement Specialist
cwatson@madisoncountyal.gov
(256) 532-6930



Addendum No. 2

Bid: 2020-27 Supervisory Control and Data Acquisition (SCADA) System Improvements

Subject: Clarifications and Changes to Bid Documents
Date: May 26, 2020
To: All Vendors

Addendum 2 includes the following:

Below are clarifications and changes to the bid documents for Bid #2020-27, Supervisory Control and Data Acquisition (SCADA) System Improvements:

5.2 SITE SPECIFIC REQUIREMENTS

(a) Raintree Tank

Raintree Tank is not currently in service but will be placed back in service upon successful completion of this project. Raintree tank has an overflow elevation that is below the HGL for the overall system. A pneumatically operated control valve will be operated to stop the tank from overflowing when it is being filled. The control valve will be operated by the proposed SCADA, with communication between the tank and valve by cell modem. A small booster pump at the base of Raintree Tank is used to fill a small in-ground tank located approximately 500' feet away from Raintree tank. No data acquisition or reporting are required for the pump control or small tank level, but an alarm for low suction side pressure (reported from the existing pump controls) should be integrated into the data sent to the master station. **The contractor shall establish new electrical service at the tank and control valve locations. The cost of Aid to Construction for Huntsville Utilities will be paid by Madison County and shall not be included in the bid costs for electrical service on the bid form.**

There is no change to the bid opening date. The bid opening is May 28, 2020 at 11:00 AM

Sincerely,

A handwritten signature in cursive script that reads "Christina Watson".

Christina Watson

Madison County Commission
Awarding Authority