



Procurement Management Department
2115 Second Floor, 1st Floor
Fort Myers, FL 33901
Main Line: (239) 533-8881
Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: June 5, 2020

Solicitation No.: B200299MIF

Solicitation Name: Sunshine Blvd. at 8th St. SW Intersection Improvements

Subject: Addendum Number 1

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date.

1. OPEN DATE/BIDS DUE EXTENSION:

FROM: June 10, 2020 at 2:30 PM

TO: June 15, 2020 at 2:30 PM

2. BID SCHEDULE:

The Bid Schedule has been updated to adjust item 660-4-12 to a quantity to 1 and a new Bid Schedule has been uploaded to the project webpage on the Lee County Procurement website.

Please ensure that your firm has downloaded the Bid Schedule and have been able to successfully use the Excel format. Any firm having compatibility issues or difficulty downloading the Bid Schedule needs to contact the Procurement Analyst for this project at their earliest convenience.

Do not wait until submission day to download! Procurement is not required to extend a closing due to Contractor delay or difficulty in receipt or download of documents.

Bidders MUST use the new Bid Schedule Excel form when submitting their bid. Failure to do so will result in Bidder being deemed non-responsive and therefore ineligible for award.

3. SHEET ADDITION

- a. Added Sheet Number T-2A to Index

4. SHEET NOTE REVISIONS: REVISED SHEETS T-1, T-2A, T-3, T-5, T-6, T-9

- a. The following note shall be considered revised and made part of the Pay Item Notes 650-1-14, 650-1-16 of Sheet T-5:

- i. **ALL SIGNAL HEAD DISPLAY LED'S SHALL HAVE A 15-YEAR WARRANTY INCLUDED. ~~ALL DISPLAYS SHALL BE EXTENDED VIEW LED DISPLAYS~~**

- b. The following note shall be considered revised and made part of the Pay Item Notes 660-4-11, 660-4-12 of Sheet T-6:

- i. **660-4-11, 660-4-12:**

- VIDEO DETECTION SHALL BE MIOVISION TRAFFLINK DETECTION WITH SMARTVIEW 360 CAMERA. THE CAMERA SHALL BE INSTALLED ON THE**

PROPOSED LUMINAIRE ARM ON POLE #1. FOR ANY FURTHER QUESTIONS, PLEASE CALL LEE COUNTY DOT TRAFFIC AT (239) 533-9500.

SEE LCDOT SPECIFICATIONS FOR MORE INFORMATION AND INSTALLATION REQUIREMENTS.

ii. 665-1-12:

ACCESSIBLE PEDESTRIAN DETECTION SHALL BE POLARA INS 2-WIRE SYSTEM:

POLARA INS2 INAVIGATOR PED STATION, POLARA ICCU-S2 (TS2 CONFIGURATION), POLARA INS INAVIGATOR PED STATION SHALL HAVE STREET NAMES PROGRAMMED BY POLARA, AND LEE COUNTY SHALL RECEIVE THE VOICE FILES DIGITALLY. CONTRACTOR SHALL BRING ICCU-S2 AND ALL INS2'S TO LEE COUNTY FOR PROGRAMMING AND SW UPGRADE IF NEEDED AND PROGRAM IP ADDRESS. LEE COUNTY WILL LABEL WHERE EACH INS2 GOES AFTER BEING PROGRAMMED. FOR ANY FURTHER QUESTIONS, PLEASE CALL LEE COUNTY DOT TRAFFIC AT (239) 533-9500.

MOUNTING HEIGHT OF PEDESTRIAN BUTTON SHALL BE FORTY-TWO (42) INCHES TO CENTER OF BUTTON ABOVE GRADE. BUTTON SHOULD BE UNDER THE HEAD IT CALLS.

BELDEN (SHIELDED) CABLE SHALL BE USED AS PEDESTRIAN DETECTOR CALL WIRE. CALL WIRES SHALL BE CONNECTED TO A PED ISOLATOR BOARD AND CHASSIS GROUND IN CABINET.

c. The following note shall be considered revised and made part of the Pay Item Notes 685-161 of Sheet T-6:

i. MODEM SHALL BE A CRADLEPOINT COR IBR1150. INCLUDE ALL INTERFACE COMPONENTS NEEDED FOR LEE COUNTY REMOTE ACCESS.

5. ATTACHMENT:

- a. **Attachment 1 - Updated Bid Schedule**
- b. **Attachment 2 – Updated RDWY Plans – B200299MIF**
- c. **Attachment 3 – Updated SIGNAL Plans – B200299MIF**

6. QUESTIONS/ANSWERS

1.	For the signs on this intersection are they to be Internally Illuminated LED or just plain metal signs rigidly mounted to a pelco arm?
Answer	Plain metal signs rigidly mounted to a pelco arm per plans.
2.	There's a line in the signal pay item notes that says, "all displays shall be extended view LED displays." Do you know if that means long life 15-yr LED, like they spec in Collier Co, or are they talking about angle of view of the module?
Answer	The Pay Item note containing "extended view LED's" can be disregarded, and the County desires a 15-year warranty period for the signal head display LED's. The PI note has been revised in Plan Revision 1 to reflect the above, dated 6/1/2020.

3.	What is the anticipated Notice to Proceed?
Answer	This project is expected to be presented to the Board of County Commissioners in October 2020 for award. A Notice to Proceed will follow shortly following Board approval of contract. Timelines of award are subject to change at the sole discretion of the County where and as deemed in its best interest.
4.	As Lee County has a preference to FDOT limerock, will only FDOT limerock be allowed on this project and all other FDOT base materials be excluded?
Answer	Please reference the specifications and revised plan set labeled Attachment 2 – Updated RDWY Plans – B200299MIF for further clarity.

Bidders must ensure they continue to monitor the Lee County Procurement website for any follow-up information regarding this solicitation.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Miguel Flores

Miguel Flores
 Procurement Analyst Direct Line: 239-533-8835
 Lee County Procurement Management