



THE SCHOOL BOARD OF MIAMI-DADE COUNTY, FLORIDA
 SCHOOL BOARD ADMINISTRATION BUILDING
 Procurement Management Services
 1450 N.E. 2nd Avenue, Room 650
 Miami, FL 33132

| |
|--|
| Direct All Inquiries To Procurement Management Services Buyer's Name: _____ PHONE: (305) 995-_____ Email: _____ TDD PHONE: (305) 995-2400 |
|--|

BID/RFP ADDENDUM

Date: _____

Addendum No. _____

BID/RFP No. _____ BID/RFP TITLE: _____

This addendum modifies the conditions of the above-referenced BID/RFP as follows:

All information, specifications terms, and conditions for the above-referenced BID/RFP, are included on the document posted on the Procurement Management website at <http://procurement.dadeschools.net>

The attached pages containing clarifications, additional information and requirements constitute an integral part of the referenced bid. If your bid/proposal has not been submitted, substitute the pages marked REVISED and mail your entire bid/proposal package.

I acknowledge receipt of Addendum Number _____

PLEASE NOTE: If your firm has forwarded a copy of this bid/proposal to another vendor, it is your responsibility to forward him/her a copy of this addendum.

(PLEASE TYPE OR PRINT BELOW)

LEGAL NAME OF BIDDER: _____

MAILING ADDRESS: _____

CITY, STATE ZIP CODE: _____

TELEPHONE NUMBER: _____ E-MAIL I.D. _____ FAX # _____

BY: SIGNATURE (Manual): _____
 OF AUTHORIZED REPRESENTATIVE

NAME (Typed): _____ TITLE: _____
 OF AUTHORIZED REPRESENTATIVE



ITB-19-037-EA Wastewater and Potable Water Treatment Facilities Questions & Answers

- 1. Please confirm that Sludge hauling is the responsibility of Miami-Dade Schools.**

Answer: *M-DCPS will use its inhouse pump trucks or the pump out term bid vendor to address the sludge hauling.*

- 2. Please confirm that the Backflow devices will be the responsibility of Miami-Dade Schools. Section 7.2.4 Schedule of Test item F 5. States that the contractor is responsible for the testing of the backflow preventors.**

Answer: *M-DCPS will test the backflow devices.*

- 3. Please confirm that the maintenance, fuel, and the exercising of the generator(s) is the responsibility of Miami-Dade Schools?**

Answer: *M-DCPS will maintain, fuel, and exercise the emergency generator.*

- 4. Please confirm whose responsibility it is to start generator when there is a loss of power? If it is the vendor's responsibility, will the School Board provide training?**

Answer: *Starting of generator will be the responsibility of the vendor. Training will be provided, but we are looking into installing a transfer switch.*

- 5. Please confirm the number of lift stations at each facility that the vendor is responsible for maintaining.**

Answer: *M-DCPS will maintain lift stations at all facilities.*

- 6. Please confirm that the vendor is responsible for supplying all the chemicals to operate the water and wastewater plants.**

Answer: *Yes, vendor is responsible for supplying all chemicals to operate the water and wastewater plants.*

- 7. Please confirm that the vendor is responsible for the cost of all routine water quality (permit required) sampling for both the water and wastewater treatment plants.**

Answer: *Yes, vendor is responsible for the cost of all routine water quality (permit required) sampling for both the water and wastewater treatment plants.*



**ITB-19-037-EA Wastewater and Potable Water Treatment Facilities
Questions & Answers**

- 8. Please confirm that the vendor is responsible for performing ground maintenance around the treatment plant with the exception of the Absorption field.**

***Answer:** Vendor is responsible for performing ground maintenance around the treatment plant with the exception of the Absorption field.*