



COUNTY OF VOLUSIA
BUSINESS SERVICES DEPARTMENT
PURCHASING & CONTRACTS DIVISION
123 West Indiana Avenue, Room 302
DeLand, Florida 32720-4608
(386) 736-5935 ♦ Fax: (386) 736-5972
www.volusia.org

July 17, 2020

ADDENDUM NO. 3

RSQ no. 20-B-145SR; C-1737
CITY ISLAND LIBRARY BUILDING RENOVATION FOR FLOOD MITIGATION

TO: All firms interested in providing the required services

The purpose of this addendum is to provide the following clarifications, changes, modifications and/or additions to the solicitation documents. This addendum is an integral part of the Solicitation/Contract Documents.

****NOTICE****

Questions/Responses:

Question: Can you verify if the attached product (Master Protect HB 200, water-based, 100% acrylic smooth waterproof coating for airless spray application, formerly Thorocoat 200) could be used instead of the epoxy?

Response: Substitute product NOT accepted.

All other terms and conditions remain unchanged.

END OF ADDENDUM NO. 3

If there are any questions, I can be reached via telephone at (386) 822-5771 or via E-mail: resto@volusia.org.

Shaira D. Resto

Shaira D. Resto, MBA, CPPB
Procurement-Contracts Manager
Purchasing and Contracts Division

Please sign and return with proposal

Vendor: _____

Signed by (Name/Position): _____

Phone No.: _____ Date: _____

FAILURE TO RETURN THIS FORM WITH THE BID SUBMITTAL MAY CAUSE THE PROPOSAL TO BE RENDERED NON-RESPONSIVE