

CITY OF SHREVEPORT-PURCHASING DIVISION

P.O. BOX 31109 SHREVEPORT, LOUISIANA 71130-1109 □ Suite 610, 505 TRAVIS SHREVEPORT, LA 71101-3042
Phone 318/673-5450 web site: www.shreveportla.gov Fax 318/673-5408

October 29, 2020

ADDENDUM #2

IFB# 20-024

New Fire Station #8

Bidders on the Project are hereby notified that this addendum shall be attached to and made part of the above named solicitation documents dated October 2, 2020. The following items are issued to add to, to modify, and/or clarify the solicitation documents. These items shall have full force and effect as the solicitation documents. Bids, to be submitted on the specified bid date, shall conform to the additions and revisions listed herein. Acknowledge receipt of all addenda received by inserting the total number received on signature page of the bid form. Failure to do so may subject the bid to being declared as non-responsive.

It shall be the bidder's responsibility to make inquiry as to any addenda issued.

Questions


- 1.0 Can you please provide additional information concerning the steel tubes and columns referred to in plan note #29, #30, and #45?

On Sheet A2.01, Plan Note #29 refers to the support pony wall at Partition Type "H". This tube column shall be a 3" x 3" x 3/8" steel tube welded to a 3/8" steel plate anchored to the floor slab. Plan Note #30 refers to the tube column at the outdoor cook area. This tube column shall also be a 3" x 3" x 3/8" steel tube. The Plan Note #45 refers to the steel columns in the engine bay. These columns shall be 6" nominal diameter, XS (Extra Strong) steel column. Field verify the required length.

- 2.0 Can you provide the sizes for lintel angles?

See Lintel Schedule in Exhibit A.

CITY OF SHREVEPORT



Wendy Wagnon, CPPO
Purchasing Agent

IFB 20-024

NEW FIRE STATION NO. 8

ADDENDUM 2

EXHIBIT A

LINTEL SCHEDULE

SUPPORTED MASONRY THICKNESS	CLEAR SPAN OPENING			
	4'-0" OR LESS	4'-1" TO 5'-4"	5'-5" TO 6'-4"	6'-5" TO 8'-0"
3 5/8"	3 1/2" X 3 1/2" X 1/4"	4" X 3 1/2" X 1/4"	5" X 3 1/2" X 5/16"	5" X 3 1/2" X 5/16"
5 5/8"	5" X 5" X 5/16"	5" X 5" X 5/16"	5" X 5" X 5/16"	5" X 5" X 5/16"
7 5/8"	(2) 3 1/2" X 3 1/2" X 1/4"	(2) 3 1/2" X 3 1/2" X 1/4"	(2) 3 1/2" X 3 1/2" X 1/4"	(2) 3 1/2" X 3 1/2" X 1/4"

1. STEEL LINTELS SHALL BE PROVIDED IN ALL OPENINGS AT MASONRY WALLS.
2. LINTEL LENGTH SHALL BE THE CLEAR SPAN OPENING PLUS A MINIMUM 6" BEARING ON EACH END.
3. LONG LEG OF LINTEL SHALL BE INSTALLED VERTICAL.