



# LABORATORY ANALYSIS REPORT

Customer	Sample	Report
<b>Company:</b> Massachusetts Bay Transportation Authority <b>Main Contact:</b> Ibrahim T. Asidah <b>Address:</b> 21 Arlington Ave, Bldg. #2 Charlestown, 02129 <b>E-mail:</b> iasidah@mbta.com	<b>ID No:</b> 236658-001 <b>Date Sampled:</b> 02/12/2020 <b>Date Received:</b> 02/28/2020 <b>Work Order:</b> <b>Purchase Order:</b> 4000092615 <b>Task No:</b>	<b>Lab Order No:</b> 236658 <b>Revision:</b> <b>Date Issued:</b> 03/20/2020 <b>Laboratory:</b> Marlborough, MA <b>Authorized By:</b>

## EQUIPMENT INFORMATION

<b>Substation:</b> 115KV Yard <b>Serial No:</b> E1100059A <b>Design Type:</b> Core Type <b>No of Phases:</b> N <b>Manufacturer:</b> EFACEC Portugal <b>Preservation:</b> Gas Blanketed <b>Alarm Set:</b>	<b>Equipment Type:</b> XFMR <b>Equipment No:</b> <b>Maximum MVA:</b> 40 <b>Cooling:</b> FA <b>Phase Name:</b> <b>Yr Manufactured:</b> 2014 <b>XFMR/TRN Type:</b> Transformer	<b>Transformer Name:</b> TA <b>Maximum KV:</b> 115.00 <b>Max. Temp Rise:</b> <b>Insulant Type:</b> Mineral <b>Volume:</b> 6012 <b>Units:</b> Gallons
--	--	---

## SAMPLING INFORMATION

<b>Syringe No:</b> <b>Container No:</b> <b>Miscellaneous ID:</b> <b>Reason for Testing:</b>	<b>Sample Date:</b> 02/12/2020 <b>Sampled By:</b> S.WALTERS <b>Time:</b> 1:55 am <b>Secondary Name:</b>	<b>Top Oil Temp (C):</b> <b>Humidity:</b> <b>Ambient Temp (C):</b> <b>Sample Point:</b> Main Tank Bottom
--	--	---

## CRITICALITY and RESAMPLE FREQUENCY

**Criticality:** Low  
**Resample Frequency:** 6 months

## Dissolved Gas Analysis

The results indicate that there is a low volume of combustible gas present.

## Oil Quality Tests

Results are acceptable.

## Additional Oil Quality Tests

## Miscellaneous Tests

This sample is considered to be 'Non-PCB' (<50 ppm) per EPA regulations listed in 40 CFR part 761.



# LABORATORY ANALYSIS REPORT

## Additional Oil Quality Tests

Serial No: E1100059A

E1100059A

Sample Date:	2/12/2020	3/27/2015
Analysis Date:	3/20/2020	
Sample Point:	Bottom	Bottom
Sample No:	1	1
Doble Sample Id:	236658-001	149622-001
Report ID:	236658	149622
Top Oil Temp (C):		13

## Additional Oil Quality Tests

Viscosity (Saybolt) (SUS)	D2161	54.9	55.0
---------------------------	-------	------	------

## Dissolved Gas Analysis

Serial No: E1100059A

E1100059A

Sample Date:	2/12/2020	3/27/2015
Analysis Date:	3/20/2020	
Sample Point:	Bottom	Bottom
Sample No:	1	1
Doble Sample Id:	236658-001	149622-001
Report ID:	236658	149622
Top Oil Temp (C):		13

## Dissolved Gas Analysis

Hydrogen (H2) (ppm)	ASTM D3612 IEC 60567	1.0^	0.0
Oxygen (O2) (ppm)	ASTM D3612 IEC 60567	587^	11000
Nitrogen (N2) (ppm)	ASTM D3612 IEC 60567	79300^	74400
Methane (CH4) (ppm)	ASTM D3612 IEC 60567	0.539^	0.600
Carbon Monoxide (CO) (ppm)	ASTM D3612 IEC 60567	5.21^	6.90
Ethane (C2H6) (ppm)	ASTM D3612 IEC 60567	0.3^	0.0
Carbon Dioxide (CO2) (ppm)	ASTM D3612 IEC 60567	305^	133
Ethylene (C2H4) (ppm)	ASTM D3612 IEC 60567	0.1^	0.0
Acetylene (C2H2) (ppm)	ASTM D3612 IEC 60567	0.0^	0.0
Total Gas (ppm)		80199^	85540
Comb. Gas (ppm)		7^	8
Est. TCG, % of Gas Space		0.01^	0.01
Ethylene-Acetylene Ratio		0.00^	0.00
PPM/Day (ppm/day)		-0.0	

## Miscellaneous Tests

Serial No: E1100059A

E1100059A

Sample Date:	2/12/2020	3/27/2015
Analysis Date:	3/20/2020	
Sample Point:	Bottom	Bottom
Sample No:	1	1
Doble Sample Id:	236658-001	149622-001
Report ID:	236658	149622
Top Oil Temp (C):		13

## Miscellaneous Tests

PCB Content (ppm)	D4059	<2	< 2
Aroclor Detected		ND	

## Oil Quality Tests

Serial No: E1100059A



# LABORATORY ANALYSIS REPORT

E1100059A

## Oil Quality Tests

	Sample Date:	2/12/2020	3/27/2015
	Analysis Date:	3/20/2020	
	Sample Point:	Bottom	Bottom
	Sample No:	1	1
	Doble Sample Id:	236658-001	149622-001
	Report ID:	236658	149622
	Top Oil Temp (C):		13
Water Content (ppm)	D1533 IEC 60814	1^	2
Relative Saturation (%)		Need Data^	5
Color D1500	D1500	L0.5^	L 0.5
Dielectric, D 877A (kV)	D877		47
Dielectric, D 1816, 1mm gap (kV)	D1816	30^	39
Interfacial Tension (mN/m)	D971	47^	47
Neut. Number (mgKOH/g)	D974	<0.01^	< 0.01
Pour Pt (°C)	D97 ISO 3016	<-40	< -40
Power Factor @ RT (%)	D924	0.024^	0.004
Power Factor @ 100°C (%)	D924	1.027^	0.135
Specific Gravity By D4052 (60/60)	D4052	0.8855^	
Specific Gravity (Rel. Density) (60/60)	D1298		0.885
Viscosity @ 40°C (mm2/s (cSt))	D445 ISO 3104	8.86	8.87
Inhibitor Content:D2668 (%)	D2668	0.300^	0.307
Visual Examination	D1524	C&B^	C&B

**Doble Engineering Marlborough, MA, Indianapolis, IN, Morrisville, NC or Morgan Schaffer is an ISO/IEC 17025 accredited laboratory**

The analyses contained in this report are based upon material and information supplied by the customer. Doble Engineering does not imply that the contents of the sample received at its laboratory are the same as all such material in the environment from which the sample was taken. Our test results only relate to the sample(s) tested. Doble Engineering assumes no responsibility and makes no warranty or representation as provided in the Doble Terms and Conditions Revision 101816. This report must not be reproduced, unless in its entirety, without the written consent of Doble Engineering. (\*Accredited Tests, tSubcontracted Tests).



# LABORATORY ANALYSIS REPORT

Customer	Sample	Report
Company: Massachusetts Bay Transportation Authority		Lab Order No: 236658
Main Contact: Ibrahim T. Asidah	ID No: 236658-002	Revision:
Address: 21 Arlington Ave, Bldg. #2	Date Sampled: 02/12/2020	Date Issued: 03/20/2020
Charlestown, 02129	Date Received: 02/28/2020	Laboratory: Marlborough, MA
E-mail: iasidah@mbta.com	Work Order:	Authorized By:
	Purchase Order: 4000092615	
	Task No:	

## EQUIPMENT INFORMATION

Equipment Information		Equipment Type: XFMR
Substation: South Boston	Equipment No:	Transformer Name: C
Serial No: 11073356	Maximum MVA: 40	Maximum KV: 115.00
Design Type:	Cooling:	Max. Temp Rise:
No of Phases: N	Phase Name:	Insulant Type:
Manufacturer: National	Yr Manufactured: 1987	Volume: 7600
Preservation: Sealed Conservator	XFMR/TRN Type:	Units: Gallons
Alarm Set:		

## SAMPLING INFORMATION

Syringe No:	Sample Date: 02/12/2020	Top Oil Temp (C): 55
Container No:	Sampled By: K.O'LEARY	Humidity: 39.00
Miscellaneous ID:	Time: 1:00 am	Ambient Temp (C): 4
Reason for Testing:	Secondary Name:	Sample Point: Main Tank Bottom

## CRITICALITY and RESAMPLE FREQUENCY

**Criticality:** Low  
**Resample Frequency:** 6 months

## Dissolved Gas Analysis

Overheating of cellulose.

## Oil Quality Tests

Water results are excellent.

## Additional Oil Quality Tests

## Miscellaneous Tests

This sample is considered to be 'Non-PCB' (<50 ppm) per EPA regulations listed in 40 CFR part 761.



# LABORATORY ANALYSIS REPORT

## Additional Oil Quality Tests

Serial No: 11073356

11073356

Sample Date:	2/12/2020	9/26/2007	3/30/2006
Analysis Date:	3/20/2020		
Sample Point:	Bottom	Bottom	Bottom
Sample No:	2	1	11
Doble Sample Id:	236658-002	77866-001	67739-011
Report ID:	236658	77866	67739
Top Oil Temp (C):	55	36	

## Additional Oil Quality Tests

Viscosity (Saybolt) (SUS)	D2161	56.0	56.2	56.0
---------------------------	-------	------	------	------

## Dissolved Gas Analysis

Serial No: 11073356

11073356

Sample Date:	2/12/2020	9/29/2010	9/26/2007	3/30/2006	10/3/2000
Analysis Date:	3/20/2020				
Sample Point:	Bottom	Bottom	Bottom	Bottom	Bottom
Sample No:	2	2	1	11	2
Doble Sample Id:	236658-002	99930-002	77866-001	67739-011	41698-002
Report ID:	236658	99930	77866	67739	41698
Top Oil Temp (C):	55	32	36		

## Dissolved Gas Analysis

Hydrogen (H2) (ppm)	ASTM D3612 IEC 60567	3.6^	0.0	3.5	6.0	0.0
Oxygen (O2) (ppm)	ASTM D3612 IEC 60567	119^	2860	1490	1880	1080
Nitrogen (N2) (ppm)	ASTM D3612 IEC 60567	43400^	48400	41100	44000	49200
Methane (CH4) (ppm)	ASTM D3612 IEC 60567	85.5^	58.0	57.0	49.0	26.0
Carbon Monoxide (CO) (ppm)	ASTM D3612 IEC 60567	252^	235	283	257	300
Ethane (C2H6) (ppm)	ASTM D3612 IEC 60567	88.4^	48.0	59.0	27.0	8.0
Carbon Dioxide (CO2) (ppm)	ASTM D3612 IEC 60567	754^	930	1030	643	596
Ethylene (C2H4) (ppm)	ASTM D3612 IEC 60567	4.1^	3.3	2.3	2.4	1.0
Acetylene (C2H2) (ppm)	ASTM D3612 IEC 60567	0.0^	0.0	0.0	0.0	0.0
Total Gas (ppm)		44707^	52534	44025	46864	51211
Comb. Gas (ppm)		434^	344	405	341	335
Est. TCG, % of Gas Space		0.50^	0.39	0.56	0.48	0.47
Ethylene-Acetylene Ratio		0.00^	0.00	0.00	0.00	
PPM/Day (ppm/day)		0.0				

## Miscellaneous Tests

Serial No: 11073356

11073356

Sample Date:	2/12/2020	9/26/2007	3/30/2006
Analysis Date:	3/20/2020		
Sample Point:	Bottom	Bottom	Bottom
Sample No:	2	1	11
Doble Sample Id:	236658-002	77866-001	67739-011
Report ID:	236658	77866	67739
Top Oil Temp (C):	55	36	

## Miscellaneous Tests

PCB Content (ppm)	D4059	<2	2	2
Aroclor Detected		ND		

## Oil Quality Tests

Serial No: 11073356



# LABORATORY ANALYSIS REPORT

11073356

## Oil Quality Tests

	Sample Date:	2/12/2020	9/26/2007	3/30/2006	10/3/2000	5/7/1999
	Analysis Date:	3/20/2020				
	Sample Point:	Bottom	Bottom	Bottom	Bottom	Bottom
	Sample No:	2	1	11	2	3
	Doble Sample Id:	236658-002	77866-001	67739-011	41698-002	37056-003
	Report ID:	236658	77866	67739	41698	37056
	Top Oil Temp (C):	55	36			
Water Content (ppm)	D1533 IEC 60814	2^	8	4	9	10
Relative Saturation (%)		1.0^	8			
Color D1500	D1500	L1.5^	1.5	1.0		
Dielectric, D 877A (kV)	D877		53	53		
Dielectric, D 1816, 1mm gap (kV)	D1816	37^	38	41		
Interfacial Tension (mN/m)	D971	39^	41	43	40	42
Neut. Number (mgKOH/g)	D974	<0.01^	0.01	0.01	0.01	0.01
Pour Pt (°C)	D97 ISO 3016	<-40	-40	-40		
Power Factor @ RT (%)	D924	0.012^	0.024	0.020		
Power Factor @ 100°C (%)	D924	0.430^	0.951	1.140		
Specific Gravity By D4052 (60/60)	D4052	0.8807^				
Specific Gravity (Rel. Density) (60/60)	D1298		0.882	0.881		
Viscosity @ 40°C (mm2/s (cSt))	D445 ISO 3104	9.19	9.22	9.18		
Inhibitor Content:D2668 (%)	D2668	N/D^	ND	ND	0.020	0.000
Visual Examination	D1524	C&B^	C&B	C&B		

**Doble Engineering Marlborough, MA, Indianapolis, IN, Morrisville, NC or Morgan Schaffer is an ISO/IEC 17025 accredited laboratory**

The analyses contained in this report are based upon material and information supplied by the customer. Doble Engineering does not imply that the contents of the sample received at its laboratory are the same as all such material in the environment from which the sample was taken. Our test results only relate to the sample(s) tested. Doble Engineering assumes no responsibility and makes no warranty or representation as provided in the Doble Terms and Conditions Revision 101816. This report must not be reproduced, unless in its entirety, without the written consent of Doble Engineering. (\*Accredited Tests, tSubcontracted Tests).



# LABORATORY ANALYSIS REPORT

Customer	Sample	Report
Company: Massachusetts Bay Transportation Authority	ID No: 236658-003	Lab Order No: 236658
Main Contact: Ibrahim T. Asidah	Date Sampled: 02/19/2020	Revision:
Address: 21 Arlington Ave, Bldg. #2	Date Received: 02/28/2020	Date Issued: 03/20/2020
Charlestown, 02129	Work Order:	Laboratory: Marlborough, MA
E-mail: iasidah@mbta.com	Purchase Order: 4000092615	Authorized By:
	Task No:	

## EQUIPMENT INFORMATION

Equipment Information	Equipment Type:	Transformer Information
Substation: SBSS	Equipment No:	Transformer Name: B
Serial No: 11073358	Maximum MVA: 40	Maximum KV: 115.00
Design Type:	Cooling:	Max. Temp Rise:
No of Phases: N	Phase Name:	Insulant Type: Mineral
Manufacturer: National	Yr Manufactured: 1987	Volume: 7650
Preservation: Gas Blanketed	XFMR/TRN Type:	Units: Gallons
Alarm Set:		

## SAMPLING INFORMATION

Syringe No:	Sample Date: 02/19/2020	Top Oil Temp (C): 50
Container No:	Sampled By: K.O'LEARY	Humidity: 28.00
Miscellaneous ID:	Time: 1:00 am	Ambient Temp (C): 4
Reason for Testing:	Secondary Name:	Sample Point: Main Tank Bottom

## CRITICALITY and RESAMPLE FREQUENCY

**Criticality:** Low  
**Resample Frequency:** 6 months

## Dissolved Gas Analysis

Overheating of cellulose.

## Oil Quality Tests

Water results are excellent. Other results are acceptable.

## Additional Oil Quality Tests

## Miscellaneous Tests

This sample is considered to be 'Non-PCB' (<50 ppm) per EPA regulations listed in 40 CFR part 761.



# LABORATORY ANALYSIS REPORT

## Additional Oil Quality Tests

Serial No: 11073358

11073358

Sample Date:	2/19/2020	9/27/2007	3/30/2006
Analysis Date:	3/20/2020		
Sample Point:	Bottom	Bottom	Bottom
Sample No:	3	3	10
Doble Sample Id:	236658-003	77866-003	67739-010
Report ID:	236658	77866	67739
Top Oil Temp (C):	50	35	

## Additional Oil Quality Tests

Viscosity (Saybolt) (SUS)	D2161	56.0	56.1	55.4
---------------------------	-------	------	------	------

## Dissolved Gas Analysis

Serial No: 11073358

11073358

Sample Date:	2/19/2020	9/29/2010	9/27/2007	3/30/2006	10/3/2000
Analysis Date:	3/20/2020				
Sample Point:	Bottom	Bottom	Bottom	Bottom	Bottom
Sample No:	3	4	3	10	4
Doble Sample Id:	236658-003	99930-004	77866-003	67739-010	41698-004
Report ID:	236658	99930	77866	67739	41698
Top Oil Temp (C):	50	32	35		

## Dissolved Gas Analysis

Hydrogen (H2) (ppm)	ASTM D3612 IEC 60567	5.3^	0.0	5.6	7.4	6.0
Oxygen (O2) (ppm)	ASTM D3612 IEC 60567	215^	4840	1320	3040	2140
Nitrogen (N2) (ppm)	ASTM D3612 IEC 60567	40000^	54200	38100	47200	41200
Methane (CH4) (ppm)	ASTM D3612 IEC 60567	77.8^	52.0	48.0	40.0	14.0
Carbon Monoxide (CO) (ppm)	ASTM D3612 IEC 60567	311^	298	368	347	372
Ethane (C2H6) (ppm)	ASTM D3612 IEC 60567	78.1^	40.0	44.0	19.0	4.0
Carbon Dioxide (CO2) (ppm)	ASTM D3612 IEC 60567	686^	878	964	639	514
Ethylene (C2H4) (ppm)	ASTM D3612 IEC 60567	3.7^	2.8	2.6	2.2	1.0
Acetylene (C2H2) (ppm)	ASTM D3612 IEC 60567	0.0^	0.0	0.0	0.0	0.0
Total Gas (ppm)		41377^	60311	40852	51295	44251
Comb. Gas (ppm)		476^	393	468	416	397
Est. TCG, % of Gas Space		0.66^	0.42	0.77	0.58	0.69
Ethylene-Acetylene Ratio		0.00^	0.00	0.00	0.00	
PPM/Day (ppm/day)		0.0				

## Miscellaneous Tests

Serial No: 11073358

11073358

Sample Date:	2/19/2020	9/27/2007	3/30/2006
Analysis Date:	3/20/2020		
Sample Point:	Bottom	Bottom	Bottom
Sample No:	3	3	10
Doble Sample Id:	236658-003	77866-003	67739-010
Report ID:	236658	77866	67739
Top Oil Temp (C):	50	35	

## Miscellaneous Tests

PCB Content (ppm)	D4059	<2	2	2
Aroclor Detected		ND		

## Oil Quality Tests

Serial No: 11073358





# LABORATORY ANALYSIS REPORT

11073358

## Oil Quality Tests

		Sample Date:	2/19/2020	9/27/2007	3/30/2006	10/3/2000	5/7/1999
		Analysis Date:	3/20/2020				
		Sample Point:	Bottom	Bottom	Bottom	Bottom	Bottom
		Sample No:	3	3	10	4	4
		Doble Sample Id:	236658-003	77866-003	67739-010	41698-004	37056-004
		Report ID:	236658	77866	67739	41698	37056
		Top Oil Temp (C):	50	35			
Water Content (ppm)	D1533 IEC 60814		3^	5	5	6	11
Relative Saturation (%)			1.7^	5			
Color D1500	D1500		L1.5^	1.5	1.0		
Dielectric, D 877A (kV)	D877			55	58		
Dielectric, D 1816, 1mm gap (kV)	D1816		33^	41	38		
Interfacial Tension (mN/m)	D971		40^	42	40	42	41
Neut. Number (mgKOH/g)	D974		<0.01^	0.01	0.01	0.01	0.01
Pour Pt (°C)	D97 ISO 3016		<-40	-40	-40		
Power Factor @ RT (%)	D924		0.018^	0.033	0.026		
Power Factor @ 100°C (%)	D924		0.661^	1.778	1.600		
Specific Gravity By D4052 (60/60)	D4052		0.8807^				
Specific Gravity (Rel. Density) (60/60)	D1298			0.882	0.881		
Viscosity @ 40°C (mm2/s (cSt))	D445 ISO 3104		9.18	9.21	9.00		
Inhibitor Content:D2668 (%)	D2668		N/D^	ND	ND	0.020	0.000
Visual Examination	D1524		C&B^	C&B	C&B		

Doble Engineering Marlborough, MA, Indianapolis, IN, Morrisville, NC or Morgan Schaffer is an ISO/IEC 17025 accredited laboratory

The analyses contained in this report are based upon material and information supplied by the customer. Doble Engineering does not imply that the contents of the sample received at its laboratory are the same as all such material in the environment from which the sample was taken. Our test results only relate to the sample(s) tested. Doble Engineering assumes no responsibility and makes no warranty or representation as provided in the Doble Terms and Conditions Revision 101816. This report must not be reproduced, unless in its entirety, without the written consent of Doble Engineering. (\*Accredited Tests, tSubcontracted Tests).



# LABORATORY ANALYSIS REPORT

Customer	Sample	Report
<b>Company:</b> Massachusetts Bay Transportation Authority <b>Main Contact:</b> Ibrahim T. Asidah <b>Address:</b> 21 Arlington Ave, Bldg. #2 Charlestown, 02129 <b>E-mail:</b> iasidah@mbta.com	<b>ID No:</b> 236658-004 <b>Date Sampled:</b> 02/19/2020 <b>Date Received:</b> 02/28/2020 <b>Work Order:</b> <b>Purchase Order:</b> 4000092615 <b>Task No:</b>	<b>Lab Order No:</b> 236658 <b>Revision:</b> <b>Date Issued:</b> 03/20/2020 <b>Laboratory:</b> Marlborough, MA <b>Authorized By:</b>

## EQUIPMENT INFORMATION

Equipment Information	Equipment Type:	Transformer Information
<b>Substation:</b> <b>Serial No:</b> 11073557 <b>Design Type:</b> <b>No of Phases:</b> <b>Manufacturer:</b> <b>Preservation:</b> <b>Alarm Set:</b>	<b>Equipment No:</b> <b>Maximum MVA:</b> <b>Cooling:</b> <b>Phase Name:</b> <b>Yr Manufactured:</b> <b>XFMR/TRN Type:</b>	<b>Transformer Name:</b> <b>Maximum KV:</b> <b>Max. Temp Rise:</b> <b>Insulant Type:</b> <b>Volume:</b> <b>Units:</b>

## SAMPLING INFORMATION

<b>Syringe No:</b> <b>Container No:</b> <b>Miscellaneous ID:</b> <b>Reason for Testing:</b>	<b>Sample Date:</b> 02/19/2020 <b>Sampled By:</b> K.O'LEARY <b>Time:</b> 1:00 am <b>Secondary Name:</b>	<b>Top Oil Temp (C):</b> 50 <b>Humidity:</b> 28.00 <b>Ambient Temp (C):</b> 4 <b>Sample Point:</b> Main Tank Bottom
--	--	--

## CRITICALITY and RESAMPLE FREQUENCY

**Criticality:** Low  
**Resample Frequency:** 6 months

## Dissolved Gas Analysis

Overheating of cellulose.

## Oil Quality Tests

Water results are excellent. Other results are acceptable.

## Additional Oil Quality Tests

## Miscellaneous Tests

This sample is considered to be 'Non-PCB' (<50 ppm) per EPA regulations listed in 40 CFR part 761.



# LABORATORY ANALYSIS REPORT

## Additional Oil Quality Tests

Serial No: 11073557

11073557

Sample Date:	2/19/2020
Analysis Date:	3/20/2020
Sample Point:	Bottom
Sample No:	4
Doble Sample Id:	236658-004
Report ID:	236658
Top Oil Temp (C):	50

## Additional Oil Quality Tests

Viscosity (Saybolt) (SUS)	D2161	56.0
---------------------------	-------	------

## Dissolved Gas Analysis

Serial No: 11073557

11073557

Sample Date:	2/19/2020
Analysis Date:	3/20/2020
Sample Point:	Bottom
Sample No:	4
Doble Sample Id:	236658-004
Report ID:	236658
Top Oil Temp (C):	50

## Dissolved Gas Analysis

Hydrogen (H2) (ppm)	ASTM D3612 IEC 60567	2.5^
Oxygen (O2) (ppm)	ASTM D3612 IEC 60567	170^
Nitrogen (N2) (ppm)	ASTM D3612 IEC 60567	33400^
Methane (CH4) (ppm)	ASTM D3612 IEC 60567	79.1^
Carbon Monoxide (CO) (ppm)	ASTM D3612 IEC 60567	230^
Ethane (C2H6) (ppm)	ASTM D3612 IEC 60567	63.0^
Carbon Dioxide (CO2) (ppm)	ASTM D3612 IEC 60567	463^
Ethylene (C2H4) (ppm)	ASTM D3612 IEC 60567	4.8^
Acetylene (C2H2) (ppm)	ASTM D3612 IEC 60567	0.0^
Total Gas (ppm)		34412^
Comb. Gas (ppm)		379^
Est. TCG, % of Gas Space		0.59^
Ethylene-Acetylene Ratio		0.00^
PPM/Day (ppm/day)		Need Data

## Miscellaneous Tests

Serial No: 11073557

11073557

Sample Date:	2/19/2020
Analysis Date:	3/20/2020
Sample Point:	Bottom
Sample No:	4
Doble Sample Id:	236658-004
Report ID:	236658
Top Oil Temp (C):	50

## Miscellaneous Tests

PCB Content (ppm)	D4059	<2
Aroclor Detected		ND

## Oil Quality Tests

Serial No: 11073557



# LABORATORY ANALYSIS REPORT

11073557

Sample Date:	2/19/2020
Analysis Date:	3/20/2020
Sample Point:	Bottom
Sample No:	4
Doble Sample Id:	236658-004
Report ID:	236658
Top Oil Temp (C):	50

## Oil Quality Tests

Water Content (ppm)	D1533 IEC 60814	1^
Relative Saturation (%)		0.6^
Color D1500	D1500	2.0^
Dielectric, D 1816, 1mm gap (kV)	D1816	34^
Interfacial Tension (mN/m)	D971	40^
Neut. Number (mgKOH/g)	D974	<0.01^
Pour Pt (°C)	D97 ISO 3016	<-40
Power Factor @ RT (%)	D924	0.025^
Power Factor @ 100°C (%)	D924	0.857^
Specific Gravity By D4052 (60/60)	D4052	0.8806^
Viscosity @ 40°C (mm2/s (cSt))	D445 ISO 3104	9.18
Inhibitor Content:D2668 (%)	D2668	N/D^
Visual Examination	D1524	C&B^

### Doble Engineering Marlborough, MA, Indianapolis, IN, Morrisville, NC or Morgan Schaffer is an ISO/IEC 17025 accredited laboratory

The analyses contained in this report are based upon material and information supplied by the customer. Doble Engineering does not imply that the contents of the sample received at its laboratory are the same as all such material in the environment from which the sample was taken. Our test results only relate to the sample(s) tested. Doble Engineering assumes no responsibility and makes no warranty or representation as provided in the Doble Terms and Conditions Revision 101816. This report must not be reproduced, unless in its entirety, without the written consent of Doble Engineering. (\*Accredited Tests, tSubcontracted Tests).