



# Oregon

Kate Brown, Governor

**Department of Corrections**

Purchasing Section

3601 State Street, Suite 280

Salem, OR 97301-5780

(971) 707-0238 (voice) 371-3161 (FAX)

Ryan.N.Kirtley@doc.state.or.us

11/24/2020



**ADDENDUM 6**  
**For**  
**291-1993-20 OSCI HVAC UPGRADE**

Below you will find Revisions, clarifications, deletions and/or additions to the bid specifications. This addendum modifies the related Invitation to Bid only to the extent specifically indicated herein. All other areas not specifically mentioned or affected by this addendum shall remain in full force and effect.

This addendum shall be added to and become part of the original Invitation to Bid.

1. Clarification; Question; A piece of equipment is receiving a controller upgrade that takes over the equipment's start/stop relay control. Does this qualify the equipment to have an air balance?  
**Answer; No, airflows are not being modified by a new start/stop signal**
2. Clarification; Question; A steam actuator is being replaced. Does this qualify the associated equipment of that actuator to have an air balance?  
**Answer; No, a steam valve is proportional, and does not effect airflows.**
3. Clarification; **Air handler dampers/actuators modified - -balancing required to ensure dampers deliver the design airflows - -such as minimum ventilation. Balancing is required whenever airflows no longer deliver original design cfms.**

This addendum represents a material change to the ITB and is required to be signed and returned by the Bid Closing Date and Time. Failure to do so may result in bid rejection.

Company Name: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_

Date: \_\_\_\_\_