



CITY OF VALDEZ
Project Title: Hospital Transfer Switch
Project No.: 20-315-1623
Contract No.: 1691

TO: All Recipients

Date: December 3, 2020

SUBJECT: Addendum No.1

This one (1) page Addendum forms a part of the project scope documents and modifies the project scope for the above-referenced project. **Acknowledge receipt of this Addendum in the space provided on the Bid Form.** Failure to do so may subject the Bidder to disqualification.

This Addendum makes the following changes and/or clarifications:

1. **Tobacco Policy:** Use of tobacco is not permitted in any part of the medical center's buildings, including patient care areas, work areas, private offices or common areas and campus including parking areas. Common areas are defined as all areas that are shared by others, such as entrances, lobbies, locker rooms, hallways, and staircases. Parking areas include the interior of vehicles. Tobacco includes cigarettes, chewing tobacco, cigars, pipe bowls and snuff. Electronic cigarettes (e-cigarettes), although they do not contain tobacco, are not allowed in the hospital setting.
2. **Question:** The plans call it a 4" conduit inside the mechanical/electrical room to the exterior MTS on the feeder schedule E3.01. (Not seeing a note specifying type of conduit for these feeders on this page) The specifications page E0.01 under "EMT" note 4 of 26 05 33 limits use to trade size 3".

Will 4" EMT as industry standard be Acceptable as is allowed per NEC 358.20B?

Answer: 4 inch EMT is acceptable for the feeders to the MTS.

End of Addendum