

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than November 23, 2020, 5:00 p.m.)

To: Chris Ellicock, Project Manager
Project Management and Development Branch
Real Estate Services Division
Phone: 916-443-9815

Email: chris.ellicock@dgs.ca.gov

PMDB RFBI No.: _____
Requestor RFBI No.: 002
Request Date: 11/23/2020
From (Bidder): GEMS

Contact: Steve Rojek
Phone: 925-671-6822 x1203
Fax: 925-671-7120
Email: srojek@gemsenvironmental.com

All RFBIs received prior to deadline identified above, and responses from the State will be published on <https://www.ospplanroom.com/>. See Details tab, Documents folder within listing.

Project No.: 00000000007087
Project Name: SDC Decommissioning Activities – UST/AST Removal
Location: Eldridge, CA

Drawing Reference: _____ Project Manual Reference: 02 65 00

Question: Project Specification Section 02 65 00 is listed twice in the project specifications, once beginning on pdf page 181, and a second time beginning on pdf page 193.

The list of tanks beginning on page 181 includes: (2) 16,920 gallon and (2) 16,453 gallon AST's; (1) 10,000 gallon UST; (1) 1,000 gallon UST; and (1) 300 gallon AST.

The list of tanks beginning on page 193 includes: (4) 12,000 gallon AST's; (1) 10,000 gallon UST; and (1) 1,000 gallon UST. These tanks were not viewed during the mandatory pre-bid site inspection on November 17.

Please clarify the quantity, size and capacity of the aboveground tanks and underground tanks that will be removed for this project.

Response: Section 02 65 00 beginning on page 181 is the correct section. The correct sizes are boxed above.

Bidder's Authorized Signature: _____
[] Check here if additional pages attached

Page 1 of 1