



CITY OF VALDEZ
Project Title: Hospital Transfer Switch
Project No.: 20-315-1623
Contract No.: 1691

TO: All Recipients

Date: December 11, 2020

SUBJECT: Addendum No.3

This one (1) page Addendum forms a part of the project scope documents and modifies the project scope for the above-referenced project. **Acknowledge receipt of this Addendum in the space provided on the Bid Form.** Failure to do so may subject the Bidder to disqualification.

This Addendum makes the following changes and/or clarifications:

- The bid date has been extended to **11:00 AM on Friday December 18, 2020.**
- **Question:** ASCO does not offer the transfer switch in NEMA 4X. The specs call for 4X. It's available in 3R (Steel) or 3RX (Stainless steel). Will 3R or 3RX be accepted?
 - **Response: A NEMA 4 or 4X (Dust-tight) is not available on these connection boxes. COV will be requiring the NEMA 3RX in 316 stainless steel to match the comparable ASCO NEMA 4X spec for a MTS.**

Substantial completion date for the project will be extended, at no cost to the owner, as needed based on lead time of materials at the time of order.

End of Addendum