



**ITB #2021-001 Wimpy's Airport Fence and Parking Area Construction
QUESTIONS & ANSWERS
CLARIFICATION ON SPECIFICATIONS
ADDENDUM 1**

Return to: Lumpkin County Board of Commissioners
Ryan McDuffie, Purchasing Agent
99 Courthouse Hill, Suite D
Dahlonega, GA 30533

Bid Closing Date: April 1, 2021 at 2:00 PM, EST
Bid Issue Date: March 3, 2021
Addendum Issue Date: March 25, 2021 at 5:00 PM, EST
Pages: 2
By: Ryan McDuffie, Purchasing Agent

Vendor Name: _____
(A copy must be attached to the Addenda Acknowledgement)

QUESTIONS

1. It appears there is a septic tank system located near the airport office. It looks like there is a possibility the field line might run under the new parking area. Is that an issue?
 - a. No.
2. During construction, if unsuitable soils are encountered under the new parking area, how will that be addressed?
 - a. Change order if necessary.
3. Section 3.1- Addendum date should be March 25, 2021 5pm.
4. Would the County prefer the use of a top rail as opposed to a tension wire on the fence?
 - a. Yes, price fence with top rail instead of tension wire.
5. The County has been made aware of an ornamental fence shortage but still desires a quote to consider this alternate.
6. Does the County have a spec on the conduit?
 - a. Sch 40, 1 ½ PVC gray conduit.



7. Will the small concrete pipe at the end of the road be replaced?
 - a. No, it will remain in place