



FLORIDA DEPARTMENT OF Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, FL 32399

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Shawn Hamilton
Interim Secretary

July 7, 2021

NOTICE TO APPLICANTS ADDENDUM NO. TWO (2)

**Wekiwa Springs State Park - Youth Camp Office
DEP Bid NO. BDC48-20/21**

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE WITH YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Alyssa Skehan, Government Operations Consultant II, Bureau of Design and Construction, 3900 Commonwealth Blvd. MS520, Tallahassee, Florida 32399-3000. Failure to do so may be grounds for rejection of the Bid.

Signature of Contractor and Date

The Following statements supersede & supplement the corresponding items in the specifications & drawings:

1. Question: Please advise if we may substitute metal stud framing for wood stud framing.

Answer: We are not allowing this substitution during the bidding period.

2. Question: The spec manual specified Architectural Products Co. gutters and downspouts in 0.032" aluminum, but this company does not offer gutters and downspouts in 0.032". They are only available in .050", .063", .080", .125" Aluminum, 22-gauge, and 24-gauge steel. I would suggest the 24-gauge steel since the panels will be 26-gauge steel. Please advise.

Answer: Gutters and downspouts should be 24-gauge galvanized steel to match roof panel finish.

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.